

Til handhafa útboðsgagna nr. 15353 – Búnaður til klórgerðar í Árbæjarlaug

Málefni: Viðauki 5 við ofangreind útboðsgögn.

Eftirfarandi fyrirspurnir hafa borist og eru svör ÍTR- Árbæjarlaug við þeim hér fyrir neðan:

Fyrirspurn 1:

What kinds of Cl/pH controllers are there that have a mA output and relay contact with adjustable hysteresis for chlorine?

Svar 1:

A PDF document (DULCOMARIN 3 Measuring and control system) is attached which show the controllers.

Fyrirspurn 2:

Which baths have a Cl/pH regulator at all?

Svar 2:

All.

Fyrirspurn 3:

How many filter installations and which baths on which filter?

Svar 3:

8 filter installations.

system 1 : 4 filters

system 2: 3 filters

system 3: 2 filters

system 4: 2 filters

system 5: 2 filters

system 6: 1 filter

system 7: 1 filter

system 8: 1 filter

Fyrirspurn 4:

Do you have flow sensors with relay contact per filter installation so that we know whether there is circulation? Contact must be made with sufficient circulation.

Svar 4:

No sensors on installations, stop signal comes from pool controls.

Fyrirspurn 5:

- We need an acid dosage per filter installation, is that possible?

Svar 5:

Must include in the unit you offer.

Vinsamlega athugið að viðauki þessi er hluti framangreindra gagna.